

SOUTH AUSTRALIA

**ELECTRICITY (PRINCIPLES OF VEGETATION CLEARANCE)
REGULATIONS 1996**

SUMMARY OF PROVISIONS

1. Citation
2. Commencement
3. Interpretation
4. Private powerlines
5. Electricity entity's duty to clear vegetation
6. Agreement between occupier and electricity entity
7. Vegetation clearance scheme agreed between council and electricity entity
8. Objections relating to vegetation clearance
9. Occupier's duty to clear vegetation
10. Planting and nurturing vegetation near powerlines
11. Exemptions from principles of vegetation clearance

SCHEDULE 1

Clearance and buffer zones around overhead powerlines

SCHEDULE 2

Planting or nurturing vegetation near public powerlines

SCHEDULE 3

Maps showing bushfire risk area

SCHEDULE 4

Transitional provisions

REGULATIONS UNDER THE ELECTRICITY ACT 1996

*Electricity (Principles of Vegetation Clearance)
Regulations 1996*

being

No. 254 of 1996: *Gaz.* 19 December 1996, p. 2045¹

¹ Came into operation 1 January 1997: reg. 2.

Citation

1. These regulations may be cited as the *Electricity (Principles of Vegetation Clearance) Regulations 1996*.

Commencement

2. These regulations will come into operation on the day on which Part 5 of the *Electricity Act 1996* comes into operation.

Interpretation

3. In these regulations, unless the contrary intention appears—

"**Act**" means the *Electricity Act 1996*;

"**buffer zone**", in relation to an overhead powerline in the bushfire risk area or on private land in a non-bushfire risk area, means the space around the powerline that adjoins the clearance zone around that powerline, as shown in the diagrams in Schedule 1;

"**bushfire risk area**" means the part of the State shown in the maps in Schedule 3 as the bushfire risk area excluding the areas shown in those maps as non-bushfire risk areas;

"**centreline**" in relation to a powerline means—

(a) in the case of an underground powerline—

- (i) that consists of a single conductor—an imaginary line on the ground directly above that conductor;
- (ii) that consists of more than one conductor—an imaginary line on the ground above the powerline that is equidistant from the outer conductors,

as indicated by markers placed by an electricity entity on the ground above the powerline;

(b) in the case of an overhead powerline—

- (i) that consists of a single conductor—an imaginary line on the ground directly beneath the position maintained by that conductor in still air;
- (ii) that consists of more than one conductor—an imaginary line on the ground below the powerline that is equidistant from the positions maintained by the outer conductors in still air;

"**clearance zone**" means the space around an overhead powerline as shown in the diagrams in Schedule 1 (the values of V, H, B, S and P referred to in those diagrams being determined by reference to the tables in that Schedule);

"**non-bushfire risk area**" means a part of the State not within the bushfire risk area;

"**public land**" means land other than private land;

3.

"span", in relation to an overhead powerline, means the part of the powerline that lies between two poles or other supports for that line.

Private powerlines

4. For the purposes of the definition of **private powerline** in the Act, the prescribed voltage is 19kV.

Electricity entity's duty to clear vegetation

5. (1) The principles of vegetation clearance set out in this regulation are prescribed for the purposes of Part 5 of the Act and govern the duty of an electricity entity to clear vegetation from around powerlines.

(2) Inspection and clearance of vegetation must take place at intervals of no longer than three years.

(3) Vegetation must be cleared from within the clearance zone that surrounds the powerline as at the time of that clearance and beyond that zone so that—

- (a) no part of the vegetation is likely to bend into that zone in winds that might reasonably be expected in the area; and
- (b) no growth or regrowth of the vegetation is likely to intrude into that zone before the next scheduled inspection and clearance.

(4) An electricity entity must not clear vegetation—

- (a) beyond the buffer zone (if any) around the powerline; nor
- (b) more than is reasonably necessary for the purposes set out in this regulation and for the purposes of enhancing the appearance and ensuring the stability and health of any remaining vegetation.

(5) However, an electricity entity may clear vegetation beyond those limits (but is not under any duty to do so) at the request of the occupier of the land on which the vegetation is situated.

(6) A request under subregulation (5) does not authorise clearance of vegetation that would be contrary to the provisions of any other law if carried out by the occupier.

Agreement between occupier and electricity entity

6. (1) An electricity entity may enter into an agreement with an occupier of land under which—

- (a) vegetation around powerlines in a specified area of the land is to be inspected and cleared more frequently than required under regulation 5;
- (b) the occupier undertakes to carry out the required inspection and clearance of vegetation on that land on behalf of the entity.

(2) The agreement—

- (a) must be in writing and executed by the occupier and the electricity entity; and

4.

- (b) must specify—
 - (i) the area concerned; and
 - (ii) the intervals at which inspection and clearance must be carried out; and
 - (iii) unless the occupier undertakes to carry out the inspections and clearance on behalf of the electricity entity—the payments agreed between the parties in respect of the costs of the additional work required under the agreement; and
- (c) may be varied or revoked by further written agreement between the parties; and
- (d) has effect, and may be enforced, as a contract between the electricity entity and the occupier.

Vegetation clearance scheme agreed between council and electricity entity

7. (1) This regulation applies to public land in a non-bushfire risk area.

(2) An electricity entity may agree a vegetation clearance scheme with a council governing the way in which the entity will carry out its duty to clear vegetation in the area of the council or part of that area.

(3) The factors that should be taken into consideration in formulating a scheme include the following:

- (a) the extent and frequency of past vegetation clearance in the area;
- (b) the nature of the vegetation, including its expected rate of growth;
- (c) the historical significance (if any) of the vegetation;
- (d) the long term effect that the clearance work would be likely to have on the health and appearance of the vegetation;
- (e) the impact that the clearance work would be likely to have on the amenity of the area;
- (f) the controls on the planting and nurturing of vegetation applicable in the area;
- (g) the limits on the financial and other resources of the electricity entity that may be devoted to the scheme and those for the areas of other councils;
- (h) any plans, or agreement between the electricity entity and the council, as to altering or removing powerlines in the area;
- (i) any arrangement between the electricity entity and the council as to the council undertaking inspections and clearance on behalf of the entity or sharing the costs involved.

(4) A scheme cannot derogate from the principles set out in regulation 5.

5.

(5) A scheme—

- (a) must be in writing and executed by the council and the electricity entity (however, separate execution is not required if the scheme is combined with an arrangement under Part 5 of the Act conferring on the council a specified role in relation to vegetation clearance); and
- (b) may be varied or revoked by written agreement between the parties.

(6) A vegetation clearance scheme as agreed has effect, and may be enforced, as a contract between the electricity entity and the council concerned.

Objections relating to vegetation clearance

8. (1) An occupier or owner of land may lodge an objection with the Minister concerning a matter set out in a notice of intention to enter land and carry out work received from an electricity entity under Part 5 of the Act.

(2) An objection under this regulation must—

- (a) be made to the Minister in writing; and
- (b) be lodged with the Minister within 30 days after receipt of the notice to which the objection relates or such further time as the Minister allows.

(3) The Minister may refuse to consider an objection on the ground that—

- (a) the subject matter of the objection is substantially the same as the subject matter of an objection previously considered; or
- (b) the objection is frivolous or vexatious or without reasonable basis; or
- (c) the occupier or owner (as the case may require) has not made a reasonable attempt to settle the matter by conciliation with the electricity entity.

(4) If the Minister decides to consider an objection, the Minister must—

- (a) notify the electricity entity of the objection; and
- (b) determine the objection or refer it to a consultative committee.

(5) An electricity entity must not, after receiving notice of an objection, carry out the clearance of vegetation to which the objection relates pending determination of the objection.

(6) The Minister may, from time to time, establish consultative committees each consisting of at least three persons, of whom—

- (a) one (the presiding officer) is a nominee of the Minister for the Environment and Natural Resources;

6.

- (b) the others are nominees of the Local Government Association of South Australia, South Australian Farmers Federation Incorporated, the Country Fire Services, the Conservation Council of South Australia Incorporated or any other interested body, as the Minister considers appropriate.

(7) A consultative committee may investigate any objection referred to it and conduct its business as it considers appropriate, but it must give the objector and the electricity entity a reasonable opportunity to be heard on the matter.

(8) A consultative committee must, within 30 days after an objection is referred to it or such further time as the Minister allows, report back to the Minister and make such recommendations as it considers appropriate on the clearance to which the objection relates and, if the Minister has so requested, on any other related matter including the alteration of the powerline in question.

(9) The Minister may, after considering an objection and, if the objection was referred to a consultative committee, the report and any recommendations of the committee—

- (a) dismiss the objection; or
- (b) direct the electricity entity to take or to refrain from taking any specified action in relation to the matter.

(10) The Minister must, as soon as practicable, notify the occupier or owner (as the case may require) of the results of the Minister's consideration of the objection.

(11) An electricity entity must, when giving notice of an intention to enter land and carry out work under Part 5 of the Act, include in or with the notice a statement of the rights of the owner or occupier to lodge objections under this regulation.

Occupier's duty to clear vegetation

9. (1) An occupier of private land must keep vegetation (other than naturally occurring vegetation) clear of any private overhead powerline on that land so that—

- (a) no part of the vegetation at any time intrudes into the clearance zone around that powerline in still air; and
- (b) no part of the vegetation is at any time likely to bend into that zone in winds that might reasonably be expected in the area.

(2) An occupier of private land is not required to clear vegetation beyond the buffer zone around any powerline.

(3) An occupier of private land must not clear vegetation which the occupier may not lawfully clear apart from this regulation—

- (a) more than is reasonably necessary for the purposes set out in subregulation (1) and for the purposes of enhancing the appearance and ensuring the stability and health of any remaining vegetation; or
- (b) in any event, beyond the buffer zone around the powerline.

Planting and nurturing vegetation near powerlines

10. For the purposes of Part 5 of the Act, Schedule 2 sets out requirements for planting or nurturing vegetation near powerlines.

Exemptions from principles of vegetation clearance

11. (1) The Technical Regulator may, on application—

- (a) exempt an occupier of land on which vegetation is planted or nurtured for commercial purposes (not including the production of timber) from compliance with regulation 9;
- (b) exempt a person from compliance with a provision of Schedule 2 in relation to specified vegetation.

(2) An application under this regulation must—

- (a) be made in a form approved by the Technical Regulator; and
- (b) contain the information specified in the form; and
- (c) be accompanied by an application fee fixed by the Minister.

(3) Before determining an application under this regulation, the Technical Regulator must give the electricity entity with the duty to keep the vegetation clear of powerlines a reasonable opportunity to make submissions and be heard on the matter.

(4) An exemption under this regulation—

- (a) must be in writing; and
- (b) may be subject to conditions, including a condition that the applicant is to pay any costs that the electricity entity incur in keeping the vegetation clear of powerlines in accordance with these regulations.

SCHEDULE 1

Clearance and buffer zones around overhead powerlines

LEGEND: Clearance zone

[Diagrams appear in
Gaz. 19.12.96, p. 2045]

Buffer zone

PART A

CLEARANCE ZONE AROUND OVERHEAD POWERLINES ON PUBLIC LAND IN A NON-BUSHFIRE RISK AREA

Diagram A

1. This diagram applies to a powerline that has conductors which are fully insulated or that is constructed to operate at a low voltage (240, 415 or 480 V).
2. The clearance zone as shown extends along the length of each span of the powerline.

[Diagrams appear in
Gaz. 19.12.96, p. 2045]

Diagram B

1. This diagram applies to a powerline the conductors of which are Insulated Unscreened Conductor ("IUC" or "CCT").
2. The clearance zone as shown extends along the length of each span of the powerline.

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram C

1. This diagram applies to a powerline, the conductors of which are not insulated, constructed to operate at a voltage of more than 480V but less than 33kV.
2. Diagram C.1 shows the clearance zone at this pole or other support at the end of each span of the powerline.
3. Diagram C.2 shows the clearance zone at mid span (as shown in diagrams C.3 & C.4) for each span of the powerline.
4. Diagrams C.3 and C.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. The values of P, V and H are set out in tables 1 and 2 in Part D.

9.

C.1—AT EACH END OF A SPAN

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.2—MID SPAN (as shown in diagrams C.3 and C.4)

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram D

1. These diagrams apply to a powerline, the conductors of which are not insulated, constructed to operate at a voltage of 33kV or more.
2. Diagram D.1 shows the clearance zone at the pole or other support at the end of each span of the powerline.
3. Diagram D.2 shows the clearance zone at mid span (as shown in diagrams D.3 and D.4) for each span of the powerline.
4. Diagrams D.3 and D.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. The values of V, H and P are set out in Tables 3 and 4 in Part D.

D.1—AT EACH END OF A SPAN

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.2—MID SPAN (as shown in diagrams D.3 and D.4)

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

11.

PART B

CLEARANCE AND BUFFER ZONE AROUND OVERHEAD POWERLINE ON PRIVATE LAND IN A NON-BUSHFIRE RISK AREA

Diagram A

1. This diagram applies to a powerline that has conductors which are fully insulated or that is constructed to operate at a low voltage (240, 415 or 480 V).
2. The zones as shown extend along the length of each span of the powerline.

[Diagrams appear in
Gaz. 19.12.96, p. 2045]

Diagram B

1. This diagram applies to a powerline the conductors of which are Insulated Unscreened Conductor ("IUC" or "CCT").
2. The zones as shown extend along the length of each span of the powerline.

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram C

1. This diagram applies to a powerline the conductors of which are not insulated, constructed to operate at a voltage of more than 480V but less than 33kV.
2. Diagram C.1 shows the zones at the pole or other support at the end of each span of the powerline.
3. Diagram C.2 shows the clearance zone at mid span (as shown in diagrams C.3 and C.4) for each span of the powerline.
4. Diagrams C.3 and C.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. Although not shown in diagrams C.3 and C.4, the buffer zone as shown in diagrams C.1 and C.2 extends along the length of each span of the powerline.
6. The values of P, V and H are set out in Tables 1 and 2 in Part D.

C.1—AT EACH END OF A SPAN

Diagram appears in
[Gaz. 19.12.96, p. 2045]

C.2—MID SPAN (as shown in diagrams C.3 and C.4)

Diagram appears in
[Gaz. 19.12.96, p. 2045]

C.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram D

1. These diagrams apply to a powerline, the conductors of which are not insulated, constructed to operate at a voltage of 33kV or more.
2. Diagram D.1 shows the zones at the pole or other support at the end of each span of the powerline.
3. Diagram D.2 shows the zones at mid span (as shown in diagrams D.3 and D.4) for each span of the powerline.
4. Diagrams D.3 and D.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. Although not shown in diagrams D.3 and D.4, the buffer zone as shown in diagrams D.1 and D.2 extends along the length of each span of the powerline.
6. The values of V, H, B and P are set out in Tables 3 and 4 in Part D.

13.

D.1—AT EACH END OF A SPAN

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.2—MID SPAN (as shown in diagrams D.3 and D.4)

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

PART C

**CLEARANCE AND BUFFER ZONE AROUND OVERHEAD POWERLINE
IN THE BUSHFIRE RISK AREA**

Diagram A

1. This diagram applies to a powerline the conductors of which are fully insulated.
2. The zones as shown extend along the length of each span of the powerline.

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram B

1. These diagrams apply to a powerline the conductors of which are Insulated Unscreened Conductor ("IUC" or "CCT").
2. The zones as shown extend along the length of each span of the powerline.

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram C

1. These diagrams apply to a powerline, the conductors of which are not insulated, constructed to operate at a voltage of less than 33kV.
2. Diagram C.1 shows the zones at the pole or other support at the end of each span of the powerline.
3. Diagram C.2 shows the zones at mid span (as shown in diagrams C.3 and C.4) for each span of the powerline.
4. Diagrams C.3 and C.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. Although not shown in diagrams C.3 and C.4, the buffer zone as shown in diagrams C.1 and C.2 extends along the length of each span of the powerline.
6. The values of V, H and P are set out in Tables 1 and 2 in Part D.

C.1—AT EACH END OF A SPAN

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.2—MID SPAN (as shown in diagrams C.3 and C.4)

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

C.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram D

1. These diagrams apply to a powerline, the conductors of which are not fully insulated, constructed to operate at a voltage from 33kV to 66kV inclusive.
2. Diagram D.1 shows the zones at the pole or other support at the end of each span of the powerline.
3. Diagram D.2 shows the zones at mid span (as shown in diagrams D.3 and D.4) for each span of the powerline.
4. Diagrams D.3 and D.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. Although not shown in diagrams D.3 and D.4, the buffer zone as shown in diagrams D.1 and D.2 extends along the length of each span of the powerline.
6. The values of V, H and P are set out in Table 3 in Part D.

D.1—AT EACH END OF A SPAN

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.2—MID SPAN (as shown in diagrams D.3 and D.4)

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

D.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

Diagram E

1. These diagrams apply to a powerline, the conductors of which are not fully insulated, constructed to operate at a voltage from 132kV to 275kV inclusive.
2. Diagram E.1 shows the zones at the pole or other support at the end of each span of the powerline.
3. Diagram E.2 shows the zones at mid span (as shown in diagrams E.3 and E.4) for each span of the powerline.
4. Diagrams E.3 and E.4 show the manner in which the clearance zone extends along the length of each span of the powerline.
5. Although not shown in diagrams E.3 and E.4, the buffer zone as shown in diagrams D.1 and D.2 extends along the length of each span of the powerline.
6. The values of V, H, S and P are set out in Table 4 in Part D.
7. The 45° component of the clearance zone is determined as being three metres inside the buffer zone.

E.1—AT EACH END OF A SPAN

[Diagram appears in
Gaz. 19.12.96, p. 2045]

E.2—MID SPAN (as shown in diagrams E.3 and E.4)

[Diagram appears in
Gaz. 19.12.96, p. 2045]

E.3—VIEW OF CLEARANCE ZONE FROM ABOVE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

E.4—VIEW OF CLEARANCE ZONE FROM SIDE

[Diagram appears in
Gaz. 19.12.96, p. 2045]

PART D
TABLES FOR DETERMINATION OF VALUE OF V, H, B, S AND P

1. The values of V, H, B, S and P are determined by the voltage at which the powerline is constructed to operate and the length of the span concerned.
2. For 132kV and 275kV lines, a "stepout" S is required for the buffer zone.
3. The values given are in metres.
4. The clearance to uninsulated LV conductors in non-bushfire risk areas is 0.1m for the length of the line and beyond termination poles or structures, as is also the case for fully insulated conductors in any part of the State.
5. The value of P determines the clearances required beyond a pole where a line terminates, in addition to clearances at poles or other support along the length of the powerline.
6. A buffer zone of 1m and no clearance zone applies where a neutral conductor (CMEN) is not within the clearance zone or buffer zone of an adjoining conductor.
7. The clearance to Insulated Unscreened Conductor ("IUC" or "CCT") is 0.5m for the length of the line and beyond termination poles or structures, in any part of the State.

TABLE 1

BARE OR COVERED CONDUCTOR AT OPERATING VOLTAGES OF 240V TO 11kV

VOLTAGE	ALL SPAN S	SPAN (in metres)									
		0-50		Over 50-100		Over 100-150		Over 150-200		Over 200	
	P	V	H	V	H	V	H	V	H	V	H
Low Voltage (240, 415 or 1480V) in bushfire risk areas only	0.5	1.0	1.0	1.5	2.5	1.5	3.5	—	—	—	—
7.6kV and 11kV in bushfire and non-bushfire risk areas	0.5	1.5	1.5	2.0	2.5	2.5	3.5	2.5	4.5	2.5	6.0

TABLE 2

BARE OR COVERED CONDUCTOR AT AN OPERATING VOLTAGE OF 19kV

VOLTAGE	ALL SPANS	SPAN (in metres)									
		0-100		Over 100-200		Over 200-300		Over 300-400		Over 400	
	P	V	H	V	H	V	H	V	H	V	H
19kV single wire earth return (SWER)	0.5	1.0	1.0	1.0	2.5	1.5	5.0	2.0	7.0	2.0	9.0

TABLE 3
BARE OR COVERED CONDUCTOR AT OPERATING VOLTAGES OF 33kV TO 66kV

VOLTAGE	SPAN (in metres)												
	All spans			0-100	Over 100-200	Over 200-300	Over 300-400	Over 400-500	Over 500-600	Over 600-700	Over 700-800	Over 800-900	Over 900
	V	P	B	H	H	H	H	H	H	H	H	H	H
33kV	2.5	0.5	2.0	2.5	4.5	6.5	9.5	14.0	19.0	25.0	32.0	39.5	48.0
66kV	3.0	1.0	2.0	2.5	4.5	6.5	9.5	14.0	19.0	25.0	32.0	39.5	48.0

TABLE 4
ALL CONDUCTORS AT OPERATING VOLTAGES OF 132kV TO 275kV

VOLTAGE	P	B	DIMENSION	SPAN (in metres)								
				0-100	Over 100-200	Over 200-300	Over 300-400	Over 400-500	Over 500-600	Over 600-700	Over 700-800	Over 800
132kV	2.5	3.0	V	3.0	4.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0
			H	3.0	6.0	10.0	14.0	20.0	28.0	37.0	47.0	58.0
			S	0	1.0	3.0	5.0	8.0	13.0	19.0	26.0	32.0
275kV	4.5	3.0	V	4.5	5.0	7.0	7.0	8.0	8.0	8.0	8.0	8.0
			H	4.5	6.0	9.0	11.0	15.0	19.0	24.0	30.0	37.0
			S	1.0	2.0	3.0	4.0	6.0	9.0	12.0	16.0	21.0

SCHEDULE 2*Planting or nurturing vegetation near public powerlines*

1. (1) Subject to clause 2, only vegetation of a kind set out in the third column of Table 1 may be planted within the distance set out in the second column from a powerline of a kind set out in the first column.

(2) Subject to clause 2, only vegetation of a kind set out in the third or fourth column of Table 1 may be nurtured if it is growing within the distance set out in the second column from a powerline of a kind set out in the first column.

2. Vegetation may be planted in proximity to a public powerline in a non-bushfire risk area and any such vegetation may be nurtured, if—

- (a) the vegetation is planted in replacement of vegetation in a stand or avenue of vegetation situated along a road; and
- (b) the vegetation is of the same species as that being replaced.

3. In this Schedule—

"**exempt vegetation**" means—

- (a) vegetation (such as small plants that produce flowers or vegetables, ground covers, cereal crops or small bushes or shrubs) with an expected mature height of less than two metres;
- (b) vegetation in relation to which an exemption is in force under these regulations;

"**prescribed distance**" means—

- (a) in the case of a powerline constructed to operate at a voltage listed below—the distance set out below in relation to that voltage:

Voltage	Distance (in metres)
500kV	19.0
275kV	12.5
132kV, other than a single pole	10.0
132kV, single pole	7.5
66kV	6.5

- (b) in any other case—six metres.

Table 1: General rules

<i>Powerline</i>	<i>Distance within which planting or nurturing is controlled</i>	<i>Vegetation which may be planted or nurtured</i>	<i>Additional vegetation which may be nurtured</i>
Overhead public powerline, the conductors of which are not insulated, in the bushfire risk area.	Prescribed distance from centreline.	Species listed in Table 2. Exempt vegetation.	Any vegetation planted or self-sown before 1 November 1988.
	More than the prescribed distance but less than twice the prescribed distance from centreline.	Species listed in Table 2 or 3. Exempt vegetation.	Any vegetation planted or self-sown before 1 November 1988.
Any other overhead public powerline.	Prescribed distance from centreline.	Species listed in Table 2 or 3. Exempt vegetation.	Any vegetation planted or self-sown before 1 November 1988.
Underground public powerline constructed to operate at a voltage of 66kv or more.	3 metres from centreline.	Species listed in Table 2 Exempt vegetation.	Any vegetation planted or self-sown before 1 November 1988.
Any other underground public powerline.	No control.		

Table 2: Vegetation with an expected mature height of 3 metres or less that may be planted in proximity to certain public powerlines

<i>Botanical Name</i>	<i>Common name</i>
<i>Abelia</i> species	
<i>Abutilon</i> species	
<i>Acacia acinacea</i>	Gold Dust Wattle
<i>Acacia anceps</i>	
<i>Acacia brachybotrya</i>	Grey Mulga
<i>Acacia cardiophylla</i>	Wyalong Wattle
<i>Acacia drummundii</i>	Drummond Wattle
<i>Acacia glaucoptera</i>	Flat Wattle
<i>Acacia glandulicarpa</i>	Hairy Pod Wattle
<i>Acacia microcarpa</i>	Manna Wattle
<i>Acacia myrtifolia</i>	Myrtle Wattle
<i>Acacia rotundifolia</i>	Round Leaf Wattle
<i>Acacia sclerophylla</i>	Hard-leaf Wattle
<i>Acokanthera oblongifolia</i>	
<i>Actinostrobilus pyramidalis</i>	Swan River Cypress
<i>Allocasuarina muelleriana</i>	
<i>Allocasuarina nana</i>	Stunted Sheoak
<i>Alyogyne</i> species	Desert Rose
<i>Alyxia buxifolia</i>	Sea Box
<i>Amelanchier sanguinea</i>	
<i>Anigozanthos</i> species	Kangaroo Paw
<i>Arundinaria</i> (cultivars) (except those in Table 3)	Ornamental Bamboos
<i>Atriplex</i> species	Saltbush
<i>Banksia caleyi</i>	Caley's Banksia
<i>Banksia dryandroides</i>	Dryandra-leaved Banksia
<i>Banksia hookeriana</i>	Hooker's Banksia
<i>Banksia nutans</i>	Nodding Banksia
<i>Banksia ornata</i>	Desert Banksia
<i>Banksia sphaerocarpa</i>	Round-fruited Banksia
<i>Beaufortia sparsa</i>	Swamp Bottlebrush
<i>Boronia</i> species (except <i>B. muelleri</i>)	
<i>Buxus sempervirens</i> (cultivars)	
<i>Callistemon</i> species (except those in Table 3 and <i>C. salignus</i>)	Bottlebrush
<i>Calothamnus</i> species	Netbush
<i>Calytrix</i> species	eg Snow Myrtle, Fringe Myrtle
<i>Camellia sasanqua</i>	
<i>Carissa bispinosa</i>	
<i>Carissa grandiflora</i>	Natal Plum
<i>Cephalotaxus harringtonia</i>	Japanese Plum-Yew
<i>Chamaecyparis lawsoniana</i> 'Ellwoodii'	
<i>Chamaecyparis lawsoniana</i> 'Olbrichi'	
<i>Chamaecyparis lawsoniana</i> 'Pottenii'	
<i>Chamaecyparis lawsoniana</i> 'Tamariscifolia'	
<i>Chamaecyparis obtusa</i> 'Aurea' (and other dwarf cultivars)	
<i>Chamaecyparis pisifera</i> 'Filifera' (and other dwarf cultivars)	
<i>Chamaerops humilis</i>	Mediterranean Palm
<i>Chamelaucium</i> species	Esperance Wax
<i>Citriobatus pauciflorus</i>	
<i>Citrus limon</i> 'Variegata'	Variegated Lemon
<i>Colletia paradoxa</i>	
<i>Coprosma repens</i>	Mirror Bush

<i>Cordyline stricta</i>	Erect Palm-Lily
<i>Cotoneaster frigidus</i>	Himalayan Cotoneaster
<i>Cortaderia rudijscula</i>	N.Z. Pink Pampass-Grass
<i>Cycas revoluta</i>	Sago-Plum
<i>Cyperus papyrus</i>	Papyrus
<i>Cyphomandra betacea</i>	Tree Tomato
<i>Cytisus</i> species (except those in Table 3 and <i>C. scoparius</i>)	
<i>Dahlia imperialis</i>	
<i>Datura cornigera</i> (<i>Brugmansia knightii</i>)	
<i>Datura sanguinea</i>	
<i>Deutzia</i> species	
<i>Dodonaea</i> species (except <i>D. viscosa</i>)	Hop Bushes
<i>Dombeya natalensis</i>	
<i>Dombeya tiliacea</i>	
<i>Doryanthes</i> species	Spear Lily
<i>Dracaena umbraculifera</i>	
<i>Duboisia hopwoodii</i>	Pituri
<i>Eremophila fraseri</i>	Turpentine Bush
<i>Eremophila mackinlayi</i>	Desert Pride
<i>Eremophila maculata</i>	Spotted Emu Bush
<i>Erica</i> species (except <i>E. arborea</i>)	Heath
<i>Eriostemon</i> species	Native Daphne, Waxflower
<i>Erythrina acanthocarpa</i>	Tambookie Thorn Tree
<i>Erythrina</i> 'Blakei'	Coral Tree
<i>Erythrina hendersonii</i>	
<i>Escallonia</i> 'C F Ball'	
<i>Escallonia</i> 'Edinburgh'	
<i>Escallonia</i> 'Fretheyi'	
<i>Escallonia</i> 'Iveyi'	
<i>Escallonia</i> x <i>langleyensis</i>	
<i>Escallonia macrantha</i>	
<i>Escallonia</i> 'Slieve Donard'	
<i>Eucalyptus kruseana</i>	Bookleaf Mallee
<i>Eucalyptus nutans</i>	Red-flowered Moort
<i>Eucalyptus pachyphylla</i>	Thick—leaved Mallee
<i>Eucalyptus preissiana</i>	Bell-fruited Mallee
<i>Eucalyptus rhodantha</i>	Rose Mallee
<i>Euonymus alata</i>	Cork Tree
<i>Euonymus hamiltoniana</i> var <i>yedeensis</i>	
<i>Euphorbia</i> species (except <i>E. candelabra</i>)	
<i>Fortunella</i> species	Cumquat
<i>Geijera linearifolia</i>	Sheep Bush
<i>Genista</i> species (except <i>G. aethnensis</i> , <i>G. virgata</i> and <i>G. monspessulanus</i>)	
<i>Goodia lotifolia</i>	Golden Tip
<i>Gordonia axillaris</i>	
<i>Gossypium barbadense</i>	Sea Island Cotton
<i>Grevillea</i> species (except those in Table 3 and <i>G. robusta</i> , <i>G. hilliana</i> and <i>G. striata</i>)	
<i>Hakea francisiana</i>	Bottlebrush Hakea
<i>Hakea leucoptera</i>	Needle Bush
<i>Hakea muelleriana</i>	Muller's Hakea
<i>Hakea nodosa</i>	Yellow Hakea
<i>Hakea orthorrhyncha</i>	
<i>Hakea sericea</i>	Silky Hakea
<i>Hakea sulcata</i>	Furrowed Hakea

<i>Hakea undulata</i>	Wavy-leaved Hakea
<i>Hesperoyucca whipplei</i>	
<i>Hibbertia</i> species	Guinea Flower
<i>Hibiscus</i> species	
<i>Hovea</i> species	
<i>Howittea trilocularis</i>	Native Hibiscus
<i>Hydrangea</i> species	
<i>Ilex cornuta</i>	Chinese Holly
<i>Ilex verticillata</i>	Black Alder
<i>Illicium floridanum</i>	Purple Anise
<i>Indigofera</i> species	
<i>Jasminum fruticans</i>	
<i>Jasminum multiflorum</i>	Hairy Jasmine
<i>Juniperus communis</i> ‘Hibernica’	Irish Juniper
<i>Juniperus sabina</i>	Savin Juniper
<i>J. x media</i> (hybrids)	
<i>Kalmia latifolia</i>	Calico Bush
<i>Kerria japonica</i>	
<i>Kolkwitzia amabilis</i>	Beauty Bush
<i>Kunzea</i> species (except <i>K. ambigua</i>)	
<i>Lantana camara</i> ‘cultivars’ (except Common Lantana)	
<i>Lavatera</i> species	
<i>Leptospermum nitidum</i> ‘Copper Sheen’	
<i>Leptospermum rotundifolium</i>	
<i>Leptospermum scoparium</i> (dwarf varieties)	
<i>Leptospermum sericeum</i>	Silver Tea Tree
<i>Leptospermum squarrosum</i>	Pink Tea Tree
<i>Leucadendron salignum</i>	
<i>Ligustrum delavayanum</i>	
<i>Ligustrum amurense</i>	Amur Privet
<i>Ligustrum japonicum</i> var. <i>rotundifolium</i>	
<i>Ligustrum ovalifolium</i> ‘Aureum’	Golden Hedge Privet
<i>Ligustrum undulatum</i>	New Guinea Privet
<i>Ligustrum vulgare</i>	European Privet
<i>Linospadix monostachus</i>	Walking-stick Palm
<i>Lonicera</i> species	Honeysuckle
<i>Macrozamia</i> species	eg Pineapple Palm
<i>Magnolia stellata</i>	Star Magnolia
<i>Maireana</i> species (Syn. <i>Kochia</i>)	eg Blue Bush
<i>Malus</i> ‘Echtermeyer’	
<i>Malus</i> ‘Gorgeous’	
<i>Malus sargentii</i>	
<i>Malvaviscus arboreus</i>	
<i>Melaleuca coccinea</i>	Goldfield’s Bottlebrush
<i>Melaleuca brevifolia</i>	White-flowered Paperbark
<i>Melaleuca decussata</i>	
<i>Melaleuca elachophylla</i>	
<i>Melaleuca elliptica</i>	Granite Honey Myrtle
<i>Melaleuca fulgens</i>	Scarlet Honey Myrtle
<i>Melaleuca gibbosa</i>	
<i>Melaleuca hamulosa</i>	
<i>Melaleuca hypericifolia</i>	Hillock Honey Myrtle
<i>Melaleuca incana</i>	Grey Honey Myrtle
<i>Melaleuca lateritia</i>	Robin Redbreast Bush
<i>Melaleuca megacephala</i>	
<i>Melaleuca micromera</i>	
<i>Melaleuca microphylla</i>	

<i>Melaleuca nematophylla</i>	Wiry Honey Myrtle
<i>Melaleuca oraria</i>	White-flowered Paperbark
<i>Melaleuca pentagona</i>	
<i>Melaleuca pulchella</i>	Claw Flower
<i>Melaleuca quadrifaria</i>	Limestone Honey Myrtle
<i>Melaleuca radula</i>	
<i>Melaleuca scabra</i>	Rough Honey Myrtle
<i>Melaleuca spathulata</i>	
<i>Melaleuca squamea</i>	Swamp Honey Myrtle
<i>Melaleuca steedmanii</i>	Steedman's Honey Myrtle
<i>Melaleuca thymifolia</i>	Thyme Honey Myrtle
<i>Melaleuca trichophylla</i>	
<i>Melaleuca uncinata</i>	Broombush Honey Myrtle
<i>Melaleuca wilsonii</i>	Wilson's Honey Myrtle
<i>Michelia figo</i>	Port Wine Magnolia
<i>Mirbelia species</i>	
<i>Miscanthus sinensis</i>	
<i>Montanoa species</i>	eg Mexican Tree Daisy
<i>Murraya paniculata</i>	
<i>Myoporum floribundum</i>	
<i>Nolina recurvata</i>	
<i>Olearia species</i>	Daisy Bush
<i>Osmanthus aurantiacus</i>	
<i>Osmanthus 'Fortunei'</i>	
<i>Osmanthus heterophyllus</i> (varieties except 'Ilicifolius')	
<i>Philadelphus species</i>	
<i>Phormium tenax</i>	N.Z. Flax
<i>Photinia glabra</i> 'Rubens'	Red-leaf Photinia
<i>Photinia 'Robusta'</i>	
<i>Picea glauca</i> var. <i>albertiana</i> 'Conica'	
<i>Pimelea species</i>	Rice Flower
<i>Plumbago auriculata</i>	
<i>Podocarpus lawrencei</i>	Mountain Plum Pine
<i>Polygala species</i>	
<i>Prostanthera species</i>	Mint Bush
<i>Protea species</i>	
<i>Prunus avium</i> 'Pendula'	Weeping Gean
<i>Prunus glandulosa</i> 'Alboplana'	Bush Cherry
<i>Prunus japonica</i>	Chinese Cherry
<i>Prunus spinosa</i> 'Purpurea'	Purple-leaf Blackthorn
<i>Prunus tenella</i> var. <i>gesslerana</i>	Dwarf Russian Almond
<i>Prunus triloba</i> 'Plena'	
<i>Psidium littorale</i>	Strawberry Guava
<i>Psoralea pinnata</i>	
<i>Pyracantha angustifolia</i>	Orange Firethorn
<i>Pyracantha coccinea</i>	
<i>Pyracantha crenulata</i>	Nepal Firethorn
<i>Pyracantha fortuneana</i>	
<i>Pyracantha rogersiana</i>	
<i>Rhamnus alaternus</i> 'Argenteovariegata'	
<i>Rhaphiolepis umbellata</i>	
<i>Rhaphiolepis x delacourii</i>	
<i>Ribes species</i>	Currant
<i>Robinia kelseyi</i>	
<i>Senna species</i> (except <i>S. brewsteri</i>)	eg Desert Cassia
<i>Sparmannia species</i>	
<i>Taxus baccata</i> 'cultivars' (except Common Yew)	

25.

Telopea mongaensis
Telopea speciosissima
Templetonia retusa
Thryptomene species
Viburnum tinus
Xylomelum angustifolium
Yucca species

Laurestinus
Sandplain Woody Pear
Yucca

Table 3: Vegetation with an expected mature height of more than 3 metres but not more than 6 metres that may be planted in proximity to certain public powerlines

<i>Botanical Name</i>	<i>Common name</i>
<i>Acacia acuminata</i>	Raspberry Jam Wattle
<i>Acacia aneura</i>	Mulga
<i>Acacia argyrophylla</i>	Golden Grey Mulga
<i>Acacia calamifolia</i>	Wallowa Wattle
<i>Acacia cultriformis</i>	Knife Leaf Wattle
<i>Acacia cyclops</i>	Western Coastal Wattle
<i>Acacia dodonaeifolia</i>	Hop-leaved Wattle
<i>Acacia gracilifolia</i>	
<i>Acacia hakeoides</i>	Hakea Leaved Wattle
<i>Acacia iteaphylla</i>	Flinders Range Wattle
<i>Acacia ligulata</i>	Umbrella Bush
<i>Acacia longifolia</i>	Sallow Wattle
<i>Acacia notabilis</i>	Notable Wattle
<i>Acacia oswaldii</i>	Umbrella Wattle
<i>Acacia rigens</i>	Nealie
<i>Acacia sophorae</i>	Coastal Wattle
<i>Acacia spectabilis</i>	Mudgee Wattle
<i>Acacia suaveolens</i>	Sweet Wattle
<i>Acacia trineura</i>	Hindmash Wattle
<i>Acacia verniciflua</i>	Varnished Wattle
<i>Acacia vestita</i>	Hairy Wattle
<i>Acacia victoriae</i>	Elegant Wattle
<i>Acer ginnala</i>	Amur Maple
<i>Acer grosseri</i>	
<i>Acer japonicum</i>	Full-moon Maple
<i>Acer palmatum</i>	Japanese Maple
<i>Acer pennsylvanicum</i>	Striped Maple
<i>Acer sieboldianum</i>	
<i>Alberta magna</i>	
<i>Aleurites fordii</i>	Tung-oil Tree
<i>Allocasuarina paludosa</i>	Scrub Sheoak
<i>Aloysia triphylla</i>	Lemon-scented Verbena
<i>Amelanchier andrachne</i>	
<i>Amelanchier asiatica</i>	
<i>Amelanchier laevis</i>	
<i>Angophora cordifolia</i> (syn. <i>A. hispida</i>)	Dwarf Apple-Myrtle
<i>Annona species</i>	Custard Apple
<i>Anopterus glandulosus</i>	Tasmanian Laurel
<i>Arbutus unedo</i>	Strawberry Tree
<i>Aristotelia serrata</i>	Makomako
<i>Arundinaria hindsii</i>	Kanzan-Chiku
<i>Arundinaria japonica</i>	Metake
<i>Arundinaria linearis</i>	Narrow-leaf Bamboo
<i>Arundo donax</i>	Danubian Reed
<i>Aesculus pavia</i>	Red Buckeye
<i>Azara lanceolata</i>	
<i>Azara microphylla</i>	Box-leaf Azara
<i>Baccharis halimifolia</i>	
<i>Bambusa multiplex</i>	Hedge Bamboo
<i>Banksia ashbyi</i>	Ashby's Banksia
<i>Banksia baueri</i>	Possum Banksia

<i>Banksia baxteri</i>	Birds-nest Banksia
<i>Banksia brownii</i>	Brown's Banksia
<i>Banksia burdettii</i>	Burdett's Banksia
<i>Banksia collina</i>	Hill Banksia
<i>Banksia media</i>	Golden Stalk
<i>Banksia speciosa</i>	Showy Banksia
<i>Bauhinia</i> species	eg Orchid Tree
<i>Betula pendula</i> 'Youngii'	Weeping Birch
<i>Boronia muelleri</i>	Tree Boronia
<i>Brachyglottis repanda</i> 'Purpurea'	
<i>Brahea armata</i>	Blue Palm
<i>Buddleja colvilei</i>	
<i>Buddleja davidii</i>	Butterfly Bush
<i>Buddleja madagascariensis</i>	
<i>Butia capitata</i>	Wine Palm
<i>Butia yatay</i>	
<i>Calliandra portoricensis</i>	
<i>Callistemon</i> 'Burgundy'	
<i>Callistemon citrinus</i>	Red Bottlebrush
<i>Callistemon</i> 'Harkness'	
<i>Callistemon phoeniceus</i>	Fiery Bottlebrush
<i>Callistemon polandii</i>	
<i>Callistemon rigidus</i>	Stiff-leaved Bottlebrush
<i>Callistemon viminalis</i>	Weeping Bottlebrush
<i>Callitris drummondii</i>	
<i>Callitris oblonga</i>	Tasmanian Cypress Pine
<i>Callitris verrucosa</i>	Mallee Pine
<i>Calpurnia aurea</i>	African Laburnum
<i>Camellia</i> species	Camellias
<i>Caryota mitis</i>	Fish Tail Palm
<i>Ceanothus</i> species	Californian Lilac
<i>Chamaecyparis lawsoniana</i> 'Allumii'	
<i>Chamaecyparis lawsoniana</i> 'Darleyensis'	
<i>Chamaecyparis lawsoniana</i> 'Fletcheri'	
<i>Chamaecyparis lawsoniana</i> 'Lutea'	
<i>Chamaecyparis lawsoniana</i> 'Stewartii'	
<i>Chamaecyparis lawsoniana</i> 'Westermanii'	
<i>Chamaecyparis obtusa</i> (except dwarf cultivars)	Golden Lawson Cypress
<i>Chamaecyparis pisifera</i> 'Argentea'	
<i>Chamaecyparis pisifera</i> 'Squarrosa'	
<i>Chamaecyparis thyoides</i> 'Glaucua'	
<i>Chamaecytisus proliferus</i>	False Tree Lucerne
<i>Chamelaucium uncinatum</i>	Geraldton Wax
<i>Chionanthus retusa</i>	
<i>Citharexylum fruticosum</i>	Florida Fiddlewood
<i>Citrus aurantifolia</i>	Sweet Lime
<i>Citrus limon</i>	Wild Lemon
<i>Citrus medica</i>	Citron
<i>Citrus reticulata</i>	Mandarin Orange
<i>Cordyline terminalis</i>	Ti-Port
<i>Cornus mas</i>	
<i>Corokia macrocarpa</i>	
<i>Corylus avellana</i>	European Hazelnut
<i>Cotinus obovatus</i>	
<i>Cotinus coggygria</i>	Smoke Tree
<i>Cotoneaster</i> 'Cornubia'	

<i>Cotoneaster</i> 'Watereri'	
<i>Cotoneaster glaucophyllus</i> (<i>C. serotinus</i>)	
<i>Crataegus chrysocarpa</i>	
<i>Crataegus coccineoides</i>	Kansas Hawthorn
<i>Crataegus crus-galli</i>	Cockspur Thorn
<i>Crataegus durobrivensis</i>	
<i>Crataegus ellwangeriana</i>	
<i>Crataegus orientalis</i>	Silver Hawthorn
<i>Crataegus phaenopyrum</i>	Washington Thorn
<i>Crataegus pinnatifida</i> var. <i>major</i>	
<i>Crataegus prunifolia</i>	Plumleaf Hawthorn
<i>Crataegus</i> x <i>grignonensis</i>	
<i>Crataegus</i> x <i>lavalleyi</i>	French Hawthorn
<i>Crinodendron hookerianum</i>	Red Lantern Tree
<i>Cupressus glabra</i> 'Hodginsii'	
<i>Cussonia spicata</i>	
<i>Cuttsia viburnea</i>	
<i>Cycas media</i>	Baveu
<i>Cytisus battandieri</i>	
<i>Cytisus multiflorus</i>	
<i>Dais cotinifolia</i>	Pompon Tree
<i>Datura arborea</i>	
<i>Datura suaveolens</i> (Burmansia)	Angels Trumpet
<i>Dicksonia antarctica</i>	Soft Tree-Fern
<i>Dodonea viscosa</i>	Hop Bush
<i>Dracaena</i> species	eg Dragon Tree
<i>Dryandra formosa</i>	
<i>Duranta</i> species	Sky Flower
<i>Elaeagnus</i> species	Russian Olive
<i>Elaeodendron australe</i>	Scarlet Olive-Wood
<i>Entelea arborescens</i>	Whau
<i>Eremophila</i> species	Emu Bush
<i>Erica arborea</i>	Tree Heath
<i>Erythrina fusca</i>	
<i>Erythrina humeana</i>	Coral Tree
<i>Erythrina parcellii</i>	Variegated Coral Tree
<i>Erythrina phlebocarpa</i>	Veined-pod Coral Tree
<i>Erythrina senegalensis</i>	
<i>Erythrina speciosa</i>	
<i>Erythrina</i> x <i>bidwillii</i>	
<i>Escallonia</i> species	
<i>Eucalyptus angulosa</i>	Ridge Fruited Mallee
<i>Eucalyptus brachycalyx</i>	Gilja or Chindoo Mallee
<i>Eucalyptus caesia</i> 'Silver Princess'	
<i>Eucalyptus calycogona</i> 'Jubilee'	Jubilee Gum
<i>Eucalyptus crucis</i>	Southern Cross Mallee
<i>Eucalyptus decipiens</i>	Limestone Marlock
<i>Eucalyptus dielsii</i>	Cap-fruited Mallee
<i>Eucalyptus dumosa</i>	White Mallee
<i>Eucalyptus erythronema</i>	Lindsay Gum
<i>Eucalyptus forrestiana</i>	Fuchsia Gum
<i>Eucalyptus gillii</i>	Curly Mallee
<i>Eucalyptus grossa</i>	Coarse-leaved Mallee
<i>Eucalyptus kingsmillii</i>	Kingsmill Mallee
<i>Eucalyptus lansdowneana</i>	Pt. Lincoln Gum & Crimson Mallee
<i>Eucalyptus macrandra</i>	Longflowered Marlock

Eucalyptus macrocarpa
Eucalyptus orbifolia
Eucalyptus pyriformis (not *E.p.youngiana*)
Eucalyptus redunca
Eucalyptus rugosa
Eucalyptus stoatei
Eucalyptus tetragona
Eucalyptus tetraptera
Eucalyptus viridis
Eucalyptus websterana
Eucryphia glutinosa
Eugenia aggregata
Eugenia uniflora
Euonymus fortunei
Euonymus japonicus
Euonymus latifolia
Euonymus pendula
Eupomatia laurina
Exochorda species
Feijoa sellowiana
Fremontodendron californicum
Garrya elliptica
Gastrolobium bilobum
Geijera parviflora
Genista aethnensis
Grevillea nematophylla
Hakea species
Hamamelis species
Hebe diosmaefolia
Hedycarya angustifolia
Hoheria lyallii
Hovenia dulcis
Howea belmoreana
Howea forsterana
Ilex crenata
Ilex paraguariensis
Ilex purpurea
Illicium anisatum
Itea ilicifolia
Jasminum mesnyi
Jasminum nudiflorum
Juniperus chinensis 'Aurea'
Juniperus communis var. *suecica*
Koelreuteria paniculata
Kunzea ambigua
Laburnum species
Lagerstroemia indica
Lantana camara
Lawsonia inermis
Leptospermum species
Leucadendron argenteum
Leucopogon parviflorus
Ligustrum japonicum
Ligustrum japonicum 'Variegatum'
Ligustrum lucidum 'Tricolor'
Ligustrum ovalifolium

Mottlecah
Round-leaved Mallee
Pear-fruited Mallee
Black Marlock
Kingscote Mallee
Scarlet Pear Gum
Tallerack
Four-winged Mallee
Green Mallee
Webster's Mallee

Rio Grande Cherry
Surinam Cherry
Spindle Tree
Evergreen Spindle Tree

Copper Laurel
Pearl Bush
Pineapple Guava
Flannel Bush

Poison Pea
Wilga
Mt. Etna Broom
Silver Leaved Water Bush
eg Oval-leaved Hakea
eg Witch Hazel

Austral Mulberry
Ribbonwood
Japanese Raisin Tree
Curly Palm
Kentia Palm
Japanese Holly
Paraguay Tree
Java Holly
Japanese Staranise

Primrose Jasmin
Winter Jasmin
Golden Chinese Juniper
Swedish Juniper
Golden Rain Tree
White Kunzea
Grafted Laburnums
Crape Myrtle
Common Lantana
Henna
Tea Tree
Silver Tree
Coast Beard-Heath
Japanese Tree Privet

Californian Privet

<i>Ligustrum sinense</i>	Chinese Privet
<i>Livistona chinensis</i>	
<i>Lophomyrtus bullata</i>	Ramarama
<i>Lophomyrtus obcordata</i>	
<i>Luculia grandifolia</i>	
<i>Magnolia liliiflora</i>	
<i>Magnolia salicifolia</i>	
<i>Magnolia sieboldii</i>	
<i>Magnolia</i> x <i>soulangeana</i> (cultivars)	Saucer Magnolia
<i>Mahonia lomariifolia</i>	
<i>Malus</i> 'Aldenhamensis'	
<i>Malus</i> 'John Downie'	
<i>Malus</i> 'Robert Nairn'	
<i>Malus</i> 'Veitch's Scarlet'	
<i>Malus angustifolia</i>	
<i>Malus halliana</i> 'Parkmanii'	
<i>Malus ioensis</i> 'Plena'	Bechtel Crab
<i>Malus sieboldii</i>	Toringo Crab
<i>Malus</i> x <i>atrosanguinea</i>	Red Japanese Crab Apple
<i>Maytenus boaria</i>	
<i>Melaleuca acuminata</i>	Mallee Honey Myrtle
<i>Melaleuca alternifolia</i>	
<i>Melaleuca bracteata</i>	White Cloud Tree
<i>Melaleuca diosmifolia</i>	
<i>Melaleuca ericifolia</i>	Swamp Paperbark
<i>Melaleuca glomerata</i>	Inland Paperbark
<i>Melaleuca halmaturorum</i>	Coastal Paperbark
<i>Melaleuca huegelii</i>	
<i>Melaleuca preissiana</i>	
<i>Melaleuca nesophila</i>	Western Honey Myrtle
<i>Meryta sinclairii</i>	
<i>Mespilus germanica</i>	Medlar
<i>Microcitrus australasica</i>	Native Finger-Lime
<i>Musa basjoo</i>	
<i>Myoporum acuminatum</i> (syn. <i>M. montanum</i>)	Water Bush
<i>Myoporum insulare</i>	Boobialla
<i>Myoporum laetum</i>	Ngaio
<i>Myrsine australis</i>	Mapou
<i>Myrtus</i> species	eg Common Myrtle
<i>Neopanax arboreus</i>	Five-Fingers
<i>Neopanax colensoi</i>	Orihou
<i>Nerium oleander</i>	
<i>Ochlandra maculata</i>	Mottled Bamboo
<i>Omalthus populifolius</i>	Queensland Poplar
<i>Osmanthus</i> species	
<i>Oxydendrum arboreum</i>	Sourwood
<i>Parrotia persica</i>	Persian Witch Hazel
<i>Photinia beauverdiana</i>	
<i>Photinia glabra</i>	
<i>Photinia villosa</i>	
<i>Phyllostachys castillonis</i>	
<i>Phyllostachys nigra</i>	Black Bamboo
<i>Phyllostachys pubescens</i>	Noble Bamboo
<i>Pisonia umbellifera</i> 'Variegata'	
<i>Pittosporum crassifolium</i>	
<i>Pittosporum eugenoides</i> 'Variegatum'	
<i>Pittosporum phylliraeoides</i>	Silver Tarata

<i>Pittosporum ralphii</i>	
<i>Pittosporum revolutum</i>	Brisbane Laurel
<i>Pittosporum tobira</i>	Tobira
<i>Plumeria rubra</i>	Frangipani
<i>Polyscias balfouriana</i>	
<i>Polyscias guilfoylei</i>	Wild Coffee
<i>Pomaderris</i> species	
<i>Poncirus trifoliata</i>	
<i>Populus</i> x <i>pseudo-grandidentata</i>	Weeping Large-tooth Aspen
<i>Prostanthera lasianthos</i>	Victorian Christmas Bush
<i>Prunus</i> 'Elvins'	
<i>Prunus amygdalus</i>	Almond
<i>Prunus cerasus</i>	Kentish Cherry
<i>Prunus cerasifera</i> 'Nigra'	
<i>Prunus ilicifolia</i>	Islay
<i>Prunus incisa</i>	Fuji Cherry
<i>Prunus lustianica</i>	Portugal Laurel
<i>Prunus mume</i> 'Alboplana'	Flowering Apricot
<i>Prunus mume</i> 'Alphandii'	Flowering Apricot
<i>Prunus persica</i> (cultivars)	Peach
<i>Prunus triloba</i>	Bush Almond
<i>Prunus</i> x <i>blireiana</i>	Cherry-Plum
<i>Pseudocydonia oblonga</i>	Quince
<i>Pseudocydonia sinensis</i>	
<i>Psidium guajava</i>	Common Guava
<i>Ptelea trifoliata</i>	Hop-Tree
<i>Punica</i> species	Pomegranate
<i>Pyracantha atalantioides</i>	Firethorn
<i>Pyrus calleryana</i>	Chinese Pear
<i>Pyrus salicifolia</i>	Silver Pear
<i>Rhododendron</i> species	
<i>Robinia hillierii</i>	
<i>Robinia pseudoacacia</i> 'Umbraculifera'	Robinia Mop Top
<i>Sambucus nigra</i>	European Elder
<i>Santalum</i> species	
<i>Senna brewsteri</i>	
<i>Sesbania grandiflora</i>	Agati
<i>Sorbus vilmorinii</i>	
<i>Spartium junceum</i>	Spanish Broom
<i>Stenolobium stans</i> (Tecoma)	
<i>Stewartia sinensis</i>	
<i>Styrax japonica</i>	Snowbell
<i>Tamarix</i> species (except <i>T. aphylla</i>)	
<i>Telopea</i> species	eg Tasmanian Waratah
<i>Thevetia peruviana</i>	Lucky Nut
<i>Thuja orientalis</i> (cultivars)	
<i>Thujopsis dolabrata</i> 'Variegata'	
<i>Tieghemopanax sambucifolius</i>	Elderberry Panax
<i>Tristanopsis laurina</i> (<i>Tristania laurina</i>)	Water Gum
<i>Ulmus glabra</i> 'Pendula'	Weeping Scotch Elm
<i>Virgilia divaricata</i>	
<i>Vitex agnus-castus</i>	Lilac Chaste Tree

SCHEDULE 3*Maps showing bushfire risk area*

The first map shows the general boundaries of the bushfire risk area for the State. The next eight maps show those boundaries in more detail.

The remaining maps show areas that fall within the general boundaries of the bushfire risk area but which are non-bushfire risk areas. Those maps are presented by district affected, in the following order:

Index to map sheets for portion of Adelaide Metropolitan Area	Jamestown	Port Lincoln
	Kadina	Port MacDonnell
	Kapunda	Port Moorowie
Metropolitan Adelaide (9 maps)	Keith	Port Vincent
	Kimba	Port Wakefield
Ardrossan	Kingscote	Port Wakefield coastline (3 maps)
Arno Bay	Kingston S.E.	Punyleroo
Balaklava	Laura	Quorn
Barossa (2 maps)	Littlehampton	Riverland (6 maps)
Beachport	Lobethal	Riverton
Blyth	Lock	Robe
Booleroo Centre	Loxton	Saddleworth
Bordertown	Lyndoch	Snowtown
Burra	Maitland	South End
Bute	Mallala	Spalding
Carrickalinga	Mannum	Strathalbyn
Ceduna	Meningie	Streaky Bay
Clare	Middleton	Tailem Bend
Cleve	Milang	Tantanoola
Coffin Bay	Millicent	Teal Flat
Coobowie	Minlaton	Terowie
Coonawarra	Minnipa	Tiddy Widdy Beach
Cowell	Moonta	Tumby Bay
Crystal Brook	Moonta Bay	Two Wells
Cummins	Mount Barker	Venus Bay
Edithburgh	Mount Gambier (2 maps)	Victor Harbor (2 maps)
Elliston	Murray Bridge	Walker flat
Eudunda	Mypolonga	Wallaroo
Eyre Peninsula East Coast (7 maps)	Naracoorte	Warooka
Fishermans Bay	Nora Creina	Woodside
Freeling	Normanville	Wool Bay
Gawler River (2 maps)	Orroroo	Wudinna
Gladstone	Penneshaw	Yorke Peninsula East Coast (5 maps)
Goolwa	Penola	Yorketown
Greenock	Peterborough	
Hahndorf	Ponde	
Hamley Bridge	Port Broughton	
Hawker	Port Elliot	
	Port Hughes	

PORTION OF SOUTH AUSTRALIA

[Index to Map Sheets and Maps 1—8 appear in *Gaz.* 19.12.96, p. 2045]

PORTION OF ADELAIDE METROPOLITAN AREA

[Index to Map Sheets and Maps 1—9 appear in *Gaz.* 19.12.96, p. 2045]

[127 Maps showing Bushfire Risk Areas appear in *Gaz.* 19.12.96, p. 2045]

SCHEDULE 4
Transitional provisions

Interpretation

1. In this Schedule—

"**revoked regulations**" means the *Electricity Trust of South Australia Regulations 1988* as adopted by the *Electricity Corporations (ETSA) Regulations 1995* immediately before the repeal of the *Electricity Corporations Act 1994*.

Agreements with occupiers

2. An agreement under regulation 7 of the revoked regulations in force immediately before the commencement of this Schedule will be taken to be an agreement under regulation 6.

Vegetation clearance schemes with councils

3. A vegetation clearance scheme under Part 3 Division 2 of the revoked regulations in force immediately before the commencement of this Schedule will be taken to be a vegetation clearance scheme agreed under regulation 7.